


PTW CHECKLIST - NO. 18	Title: Use of 230V Electrical Equipment in a Hazardous Area	
Owner: Permit System Manager		
Approver: Permit System Manager	Max Validity Period: 5 years	
Permit No.:	Date:	

Latest Rev	Date	Details	Authorised By
5.0	July 2021	Full Revision	M Birdsall

Other Checklists That May Be Relevant: 17, 27
HRA Checklists:

NOTE: This check sheet is not used for battery operated tools, meters, or equipment.

Tick when done

	Y	N	NA
1. All equipment checked and found to be in good condition with a current test tag.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. ELCB or RCD.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Cables run through a hazardous area are fitted with an orange, hazardous area extension lead tag. Note a registered electrician must fit these tags.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>